



Regional District of Nanaimo - Utilities Department

Madrona Water Analysis - Monthly Report

Date	Sample Location (Address)	Fecal Coli * Health Dep	Total Coli * Health Dep	Total Coli RDN	E Coli RDN	Temp ° C	pH	Cl <sub>2</sub> ppm	TDS ppm	Sal %	Cond uS/cm	Fe ppm	Mn ppm
1-Feb	1566 Arbutus	0	0	0	0	8	7.1	0.02	162	0.2	346	0.05	0.032
8-Feb	1825 NW Bay Rd	0	0	0	0	8	6.9	0.02	160	0.2	337		
15-Feb	1358 Madrona	0	0	0	0	7	7	0.02	165	0.2	353		
22-Feb	1566 Arbutus			0	0	7	7.1	0.04	161	0.2	343		
	<b>Average</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>7.5</b>	<b>7.0</b>	<b>0.03</b>	<b>162.0</b>	<b>0.2</b>	<b>344.8</b>	<b>0.05</b>	<b>0.032</b>
	<b>Maximum</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>8</b>	<b>7.1</b>	<b>0.04</b>	<b>165</b>	<b>0.2</b>	<b>353</b>	<b>0.05</b>	<b>0.032</b>
	<b>Minimum</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>7</b>	<b>6.9</b>	<b>0.02</b>	<b>160</b>	<b>0.2</b>	<b>337</b>	<b>0.05</b>	<b>0.032</b>

Red font indicates non-compliance with Canadian Drinking Water Guidelines / BC Approved Water Quality Guidelines

Coliforms are measured in colony forming units (CFU) per 100 millilitres of water

\* Yellow Column Coliform tests are done by Health Department

Green tests are completed by RDN

Regional District of Nanaimo - Utilities Department

Madrona Water Analysis - Monthly Report

Date	Sample Location (Address)	Fecal Coli * Health Dep	Total Coli * Health Dep	Total Coli RDN	E Coli RDN	Temp ° C	pH	Cl <sub>2</sub> ppm	TDS ppm	Sal %	Cond uS/cm	Fe ppm	Mn ppm
1-Mar	1825 NW Bay Rd	0	0	0	0	8	7.3	0.05	161	0.2	340	0.01	0.009
8-Mar	1566 Arbutus Dr	0	0			8	7.6	0.04	161	0.2	338		
15-Mar	1358 Madrona Dr	0	0	0	0	9	7.3	0.03	169	0.2	356		
	<b>Average</b>	0	0	0	0	8.3	7.4	0.04	163.7	0.2	344.7	0.01	0.009
	<b>Maximum</b>	0	0	0	0	9	7.6	0.05	169	0.2	356	0.01	0.009
	<b>Minimum</b>	0	0	0	0	8	7.3	0.03	161	0.2	338	0.01	0.009

Red font indicates non-compliance with Canadian Drinking Water Guidelines / BC Approved Water Quality Guidelines

Coliforms are measured in colony forming units (CFU) per 100 millilitres of water

\* Yellow Column Coliform tests are done by Health Department

Green tests are completed by RDN



# Regional District of Nanaimo - Utilities Department

## Madrona Water Analysis - Monthly Report



Date Apr-05	Sample Location (Address)	Fecal Coli * Health Dep	Total Coli * Health Dep	Total Coli RDN	E Coli RDN	Temp ° C	pH	Cl <sub>2</sub> ppm	TDS ppm	Sal %	Cond uS/cm	Fe ppm	Mn ppm
5-Apr	1566 Arbutus	0	0	0	0	9	7.2	0.04	163	0.2	347	0.05	0.031
12-Apr	1825 NW Bay Rd	0	0	0	0	9	7.2	0.04	160	0.2	339		
19-Apr	1358 Madrona Dr			0	0	10	7.1	0.01	163	0.2	343		
26-Apr	1566 Arbutus			0	0	11	7.2	0.07	165	0.2	346		
	<b>Average</b>	0	0	0	0	9.8	7.2	0.04	162.8	0.2	343.8	0.05	0.031
	<b>Maximum</b>	0	0	0	0	11	7.2	0.07	165	0.2	347	0.05	0.031
	<b>Minimum</b>	0	0	0	0	9	7.1	0.01	160	0.2	339	0.05	0.031

Red font indicates non-compliance with Canadian Drinking Water Guidelines / BC Approved Water Quality Guidelines

Coliforms are measured in colony forming units (CFU) per 100 millilitres of water

\* Yellow Column Coliform tests are done by Health Department

Green tests are completed by RDN

**Comments:**

Not all bacteria test results are returned from Health Department therefore some data may be missing.

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Utilities Department

## Vall Beach Water Analysis - Monthly Report



Date	Sample Location (Address)	Fecal Coli * Health Dep	Total Coli * Health Dep	Total Coli RDN	E Coli RDN	Temp °C	pH	Cl <sub>2</sub> ppm	TDS ppm	Sal %	Cond uS/cm	Fe ppm	Mn ppm
3-May	1825 NW Bay	0	0	0	0	11	7.5	0.04	159	0.2	333	0.03	0.021
10-May	1358 Madrona	0	0	0	0	12	7	0.02	167	0.2	350		
17-May	1566 Arbutus	0	0	0	0	13	7.2	0.02	162	0.2	341		
25-May	1825 NW Bay			1	0	13	6.9	0.03	120	0.1	252		
31-May	1566 Arbutus			0	0	13	6.9	0.03	35	0	74.3		
	<b>Average</b>	0	0	0.2	0	12.4	7.1	0.03	128.6	0.1	270.1	0.03	0.021
	<b>Maximum</b>	0	0	1	0	13	7.5	0.04	167	0.2	350	0.03	0.021
	<b>Minimum</b>	0	0	0	0	11	6.9	0.02	35	0	74.3	0.03	0.021

Red font indicates non-compliance with Canadian Drinking Water Guidelines / BC Approved Water Quality Guidelines

Coliforms are measured in colony forming units (CFU) per 100 millilitres of water

\* Yellow Column Coliform tests are done by Health Department

Green tests are completed by RDN

**Comments:**

Not all bacteria test results are returned from Health Department therefore some data may be missing

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Utilities Department

## Wall Beach Water Analysis - Monthly Report



Date	Sample Location (Address)	Fecal Coli * Health Dep	Total Coli * Health Dep	Total Coli RDN	E Coli RDN	Temp ° C	pH	Cl <sub>2</sub> ppm	TDS ppm	Sal %	Cond uS/cm	Fe ppm	Mn ppm
7-Jun	1825 NW Bay	0	0	0	0	13	7.1	0.09	163	0.2	342	0.21	0.124
14-Jun	1358 Madrona	0	0	0	0	14	6.8	0.03	44	0	94.4		
21-Jun	1566 Arbutus	0	0	0	0	14	6.7	0.05	40	0	83.9		
28-Jun	1825 NW Bay			1	0	14	7.2	0.05	133	0.1	281		
	<b>Average</b>	0	0	0.25	0	13.8	7.0	0.06	95.0	0.1	200.3	0.21	0.124
	<b>Maximum</b>	0	0	1	0	14	7.2	0.09	163	0.2	342	0.21	0.124
	<b>Minimum</b>	0	0	0	0	13	6.7	0.03	40	0	83.9	0.21	0.124

Red font indicates non-compliance with Canadian Drinking Water Guidelines / BC Approved Water Quality Guidelines

Coliforms are measured in colony forming units (CFU) per 100 millilitres of water

\* Yellow Column Coliform tests are done by Health Department

Green tests are completed by RDN

**Comments:**

Not all bacteria test results are returned from Health Department therefore some data may be missing.  
 Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Utilities Department

## Vall Beach Water Analysis - Monthly Report

Date Jul-05	Sample Location (Address)	Fecal Coli * Health Dep	Total Coli * Health Dep	Total Coli RDN	E Coli RDN	Temp ° C	pH	Cl <sub>2</sub> ppm	TDS ppm	Sal %	Cond uS/cm	Fe ppm	Mn ppm
5-Jul	1358 Madrona	0	0	0	0	16	7	0.04	51	0.1	108.7	0.06	0.004
12-Jul	1566 Arbutus	0	0	0	0	16	6.5	0.06	42	0	88		
19-Jul	1825 NW Bay	0	6	2	0	18	6.9	0.03	49	0	104.4		
26-Jul	1358 Madrona			0	0	17	6.8	0.04	54	0.1	113.9		
	<b>Average</b>	0	2	0.5	0	16.8	6.8	0.04	49.0	0.1	103.8	0.06	0.004
	<b>Maximum</b>	0	6	2	0	18	7	0.06	54	0.1	113.9	0.06	0.004
	<b>Minimum</b>	0	0	0	0	16	6.5	0.03	42	0	88	0.06	0.004

Red font indicates non-compliance with Canadian Drinking Water Guidelines / BC Approved Water Quality Guidelines

Coliforms are measured in colony forming units (CFU) per 100 millilitres of water

\* Yellow Column Coliform tests are done by Health Department

Green tests are completed by RDN

**Comments:**

**Not all bacteria test results are returned from Health Department therefore some data may be missing.**

**Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.**



# Regional District of Nanaimo - Utilities Department

## Wall Beach Water Analysis - Monthly Report

Date	Sample Location (Address)	Fecal Coli * Health Dep	Total Coli * Health Dep	Total Coli RDN	E Coli RDN	Temp ° C	pH	Cl <sub>2</sub> ppm	TDS ppm	Sal %	Cond uS/cm	Fe ppm	Mn ppm
3-Aug	1566 Arbutus	0	0	1	0	19	6.8	0.04	53	0.1	111.4	0.12	0.014
9-Aug	1825 NW Bay Rd	0	0	BG	0	18	7	0.03	75	0.1	157.4		
16-Aug	1358 Madrona	0	0	0	0	18	6.8	0.04	50	0.1	105.7		
23-Aug	1566 Arbutus			0	0	18	6.8	0.08	47	0	100.5		
30-Aug	1819 NW Bay Rd			0	0	18	6.8	0.09	47	0	98.3		
	<b>Average</b>	0	0	0.25	0	18.2	6.8	0.06	54.4	0.1	114.7	0.12	0.014
	<b>Maximum</b>	0	0	1	0	19	7	0.09	75	0.1	157.4	0.12	0.014
	<b>Minimum</b>	0	0	0	0	18	6.8	0.03	47	0	98.3	0.12	0.014

Red font indicates non-compliance with Canadian Drinking Water Guidelines / BC Approved Water Quality Guidelines

Coliforms are measured in colony forming units (CFU) per 100 millilitres of water

\* Yellow Column Coliform tests are done by Health Department

Green tests are completed by RDN

**Comments:**

Not all bacteria test results are returned from Health Department therefore some data may be missing.

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.





# Regional District of Nanaimo - Utilities Department

## Wall Beach Water Analysis - Monthly Report

Date Sep-05	Sample Location (Address)	Fecal Coli * Health Dep	Total Coli * Health Dep	Total Coli RDN	E Coli RDN	Temp ° C	pH	Cl <sub>2</sub> ppm	TDS ppm	Sal %	Cond uS/cm	Fe ppm	Mn ppm
7-Sep	1358 Madrona			0	0	17	6.8	0.09	49	0	103	0.12	0.001
13-Sep	1566 Arbutus			0	0	17	6.9	0.09	47	0	99		
20-Sep	1819 NW Bay			0	0	17	6.8	0.04	52	0.1	110.5		
27-Sep	1358 Madrona			0	0	16	6.8	0.07	56	0.1	118		
<b>Average</b>		#DIV/0!	#DIV/0!	0	0	16.8	6.8	0.07	51.0	0.1	107.6	0.12	0.001
<b>Maximum</b>		0	0	0	0	17	6.9	0.09	56	0.1	118	0.12	0.001
<b>Minimum</b>		0	0	0	0	16	6.8	0.04	47	0	99	0.12	0.001

Red font indicates non-compliance with Canadian Drinking Water Guidelines / BC Approved Water Quality Guidelines

Coliforms are measured in colony forming units (CFU) per 100 millilitres of water

\* Yellow Column Coliform tests are done by Health Department

Green tests are completed by RDN

**Comments:**

Not all bacteria test results are returned from Health Department therefore some data may be missing.

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern



# Regional District of Nanaimo - Utilities Department

## Wall Beach Water Analysis - Monthly Report

Date	Sample Location (Address)	Fecal Coli * Health Dep	Total Coli * Health Dep	Total Coli RDN	E Coli RDN	Temp ° C	pH	Cl <sub>2</sub> ppm	TDS ppm	Sal %	Cond uS/cm	Fe ppm	Mn ppm
4-Oct	1566 Arbutus			1	0	15	6.8	0.03	114	0.1	240	0.1	0.022
12-Oct	1819 NW Bay			0	0	12	7.5	0.04	150	0.1	315		
18-Oct	1358 Madrona			0	0	14	7.1	0.03	160	0.2	335		
25-Oct	1566 Arbutus			0	0	12	6.9	0.03	153	0.2	324		
	<b>Average</b>			0.25	0	13.3	7.1	0.03	144.3	0.2	303.5	0.10	0.022
	<b>Maximum</b>			1	0	15	7.5	0.04	160	0.2	335	0.1	0.022
	<b>Minimum</b>			0	0	12	6.8	0.03	114	0.1	240	0.1	0.022

Red font indicates non-compliance with Canadian Drinking Water Guidelines / BC Approved Water Quality Guidelines

Coliforms are measured in colony forming units (CFU) per 100 millilitres of water

\* Yellow Column Coliform tests are done by Health Department

Green tests are completed by RDN

**Comments:**

Not all bacteria test results are returned from Health Department therefore some data may be missing.

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Utilities Department

## Wall Beach Water Analysis - Monthly Report

Date	Sample Location (Address)	Fecal Coli * Health Dep	Total Coli * Health Dep	Total Coli RDN	E Coli RDN	Temp ° C	pH	Cl <sub>2</sub> ppm	TDS ppm	Sal %	Cond uS/cm	Fe ppm	Mn ppm
1-Nov	1819 NW Bay	0	0	0	0	10	7.1	0.06	154	0.2	326	0.02	0.015
8-Nov	1358 Madrona	0	0	0	0	13	7.3	0.03	160	0.2	337		
15-Nov	1566 Arbutus	0	0	0	0	10	7.4	0.06	152	0.2	323		
22-Nov	1819 NW Bay			0	0	9	7.1	0.03	150	0.1	317		
29-Nov	1358 Madrona			0	0	10	7.3	0.05	156	0.2	331		
	<b>Average</b>	0	0	0	0	10.4	7.2	0.05	154.4	0.2	326.8	0.02	0.015
	<b>Maximum</b>	0	0	0	0	13	7.4	0.06	160	0.2	337	0.02	0.015
	<b>Minimum</b>	0	0	0	0	9	7.1	0.03	150	0.1	317	0.02	0.015

Red font indicates non-compliance with Canadian Drinking Water Guidelines / BC Approved Water Quality Guidelines

Coliforms are measured in colony forming units (CFU) per 100 millilitres of water

\* Yellow Column Coliform tests are done by Health Department

Green tests are completed by RDN

**Comments:**

Not all bacteria test results are returned from Health Department therefore some data may be missing.

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern



# Regional District of Nanaimo - Utilities Department

## Westbay Water Analysis - Monthly Report

Date	Sample Location (Address)	Fecal Coli * Health Dep	Total Coli * Health Dep	Total Coli RDN	E Coli RDN	Temp ° C	pH	Cl <sub>2</sub> ppm	TDS ppm	Sal %	Cond uS/cm	Fe ppm	Mn ppm
06-Dec	2315 Ida Ln	0	0	0	0	10	7.0	0.06	162	0.2	342	0.12	0.176
13-Dec	2450 Nanoose			0	0	9	6.9	0.14	170	0.2	358		
20-Dec	2315 Ida Ln					10	7.2	0.08	171	0.2	362		
	<b>Average</b>	0	0	0	0	9.7	7.0	0.09	167.7	0.2	354.0	0.12	0.176
	<b>Maximum</b>	0	0	0	0	10	7.2	0.14	171	0.2	362	0.12	0.176
	<b>Minimum</b>	0	0	0	0	9	6.9	0.06	162	0.2	342	0.12	0.176

Red font indicates non-compliance with Canadian Drinking Water Guidelines / BC Approved Water Quality Guidelines

Coliforms are measured in colony forming units (CFU) per 100 millilitres of water

\* Yellow Column Coliform tests are done by Health Department

Green tests are completed by RDN

**Comments:**

Not all bacteria test results are returned from Health Department therefore some data may be missing.

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern