

North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: Regional District of Nanaimo
Attn: Heather Dorken
6300 Hammond Bay Rd
Nanaimo, BC
V9T 6N2

Lab Number: 92283
Date Reported: 23 Dec 11
Date Completed: 23 Dec 11
Date Received: 13 Dec 11 9:26

92283-01 962 Surfside Drive treated

Sampled By: H.Dorken / L. Jaworski

Sampling Date: 12 Dec 11 10:00

Test	Result	Units	Drinking Water Guideline
Total Coliforms (DES)	<1.0	MPN/100mL	<1
E. coli (DES)	<1.0	MPN/100mL	<1

92283-02 Surfside #1 well water

Sampled By:

Sampling Date: 12 Dec 11 10:43

Test	Result	Units	Drinking Water Guideline
Chloride	5.8	mg/L	250 AO
Conductivity	137.4	uS/cm	
T-Sodium	5.11	mg/L	200 AO
Total Coliforms (DES)	<1.0	MPN/100mL	<1
E. coli (DES)	<1.0	MPN/100mL	<1
Total Dissolved Solids	76	mg/L	500 AO

92283-03 Surfside #2 well water

Sampled By:

Sampling Date: 12 Dec 11 10:24

Test	Result	Units	Drinking Water Guideline
Chloride	5.3	mg/L	250 AO
Conductivity	130.8	uS/cm	
T-Sodium	5.74	mg/L	200 AO
Total Coliforms (DES)	<1.0	MPN/100mL	<1
E. coli (DES)	<1.0	MPN/100mL	<1

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC


> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

12/23/2011 14:20

Page 1 of 3



North Island Laboratories


• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

92283-03 Surfside #2 well water

Sampled By:

Sampling Date: 12 Dec 11 10:24

Test	Result	Units	Drinking Water Guideline
Total Dissolved Solids	68	mg/L	500 AO



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: Regional District of Nanaimo
Lyndon Jaworski

Lab Number: 92470
Date Reported: 22 Dec 11
Date Completed: 22 Dec 11
Date Received: 21 Dec 11 13:29

92470-01 1081 Surfside treated

Sampled By: L Jaworski
Sampling Date: 21 Dec 11 9:53

Test	Result	Units	Drinking Water Guideline
Total Coliforms (DES)	<1.0	MPN/100mL	<1
E. coli (DES)	<1.0	MPN/100mL	<1

92470-02 Surfside #1 well water

Sampled By: L Jaworski
Sampling Date: 21 Dec 11 10:20

Test	Result	Units	Drinking Water Guideline
Total Coliforms (DES)	<1.0	MPN/100mL	<1
E. coli (DES)	<1.0	MPN/100mL	<1

92470-03 Surfside #2 well water

Sampled By: L Jaworski
Sampling Date: 21 Dec 11 10:07

Test	Result	Units	Drinking Water Guideline
Total Coliforms (DES)	<1.0	MPN/100mL	<1
E. coli (DES)	<1.0	MPN/100mL	<1

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC
> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced,
except in its entirety, without written consent from the laboratory.
Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

12/22/2011 12:05

Page 1 of 2