

Request for Tenders - Addendum No. 2

Coombs - Hilliers Fire Department Water Storage Tank

Issued Date: November 29, 2018

The following information is provided as additions to the request for tenders to answer questions raised by Potential Proponents for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Proponent or any sub-Proponent not being familiar with this Addendum.

- 1. Horizontal water steel tank to be fabricated to API 650 or CAN/ULC-S601 with minimum 3/8" thick walls, A36 steel.
- 2. Remove and replace Section E of the General Work Scope in its entirety with:

Two welded 250mm (10") flange air vents c/w gooseneck and bird / vermin screen.

Proponents shall acknowledge receipt and acceptance of this Addendum No. 2 by signing in the space provided and emailing the signed Addendum to:

msquire@rdn.bc.ca

END OF ADDENDUM NO. 2

Signature	Date