



Addendum #1: Request for Proposals

Professional Engineering Services

For The

RDN Water Services SCADA Master Plan

This addendum (Addendum #1) is a compilation of questions received from possible proponents up to 4:30pm on March 1st, 2018, and the answers to these questions.

1) Question:

What hardware / software platforms are currently deployed at these various sites?

Answer:

At the Nanoose WTP the current operating system is Win-XP and the SCADA software is RSLogix 5000, rev. 19, with RS View 32. The PLCs at the WTP are Allen Bradley.

The remote stations located throughout the 9 water systems contain a variety of hardware and software. Many of the recent control system upgrades have involved installation of a SCADPAC to help make some sites "SCADA ready".

It is the responsibility of the consultant, as per Section 2.1.1 of the Request for Proposals, to compile a record of the existing hardware and software installations for all the water systems.

End of Addendum #1