

Nanoose # 3 - Well Data - Depth 156.5 ft / 47.7 m

2006	Average Capacity (m ³ /min)	Discharge pressure (psi)	Static level (ft)	Static level (m)	Pumping level (ft)	Pumping Level (m)	Drawdown n (m)	Meter reading (m ³)	Monthly Consumption (m ³)	Hour Meter	Total Hours	Water over pump		
												Level (m)	Level Low	Level Critical
Jan-06	#DIV/0!	off	141.6	43.16	141.1	43.01	-0.15	32616	0	2787.6	0	5.19	no	no
Feb-06	0.151	off	141.1	43.01	141.5	43.13	0.12	32616	631	2787.6	69.6	5.07	no	no
Mar-06	0.153	22	140.9	42.95	148.3	45.20	2.26	33247	1507	2857.2	164.5	3.00	no	no
Apr-06	0.141	off	140.9	42.95	148.4	45.23	2.29	34754	155	3021.7	18.3	2.97	no	no
May-06	#DIV/0!	off	140.8	42.92	141	42.98	0.06	34909	0	3040	0	5.22	no	no
Jun-06	#DIV/0!	off	140.8	42.92	141.1	43.01	0.09	34909	0	3040	0	5.19	no	no
Jul-06	#DIV/0!	off	140.8	42.92	141.5	43.13	0.21	34909	0	3040	0	5.07	no	no
Aug-06	#DIV/0!	off	141.3	43.07	141.9	43.25	0.18	34909	0	3040	0	4.95	no	no
Sep-06	0.173	off	142	43.28	149.7	45.63	2.35	34909	918	3040	88.3	2.57	no	no
Oct-06	0.188	20	142	43.28	150.4	45.84	2.56	35827	1750	3128.3	155.5	2.36	no	no
Nov-06	0.203	20	141.5	43.13	150.2	45.78	2.65	37577	1830	3283.8	150.5	2.42	no	no
Dec-06	0.212	22	141.4	43.10	150.1	45.75	2.65	39407	3110	3434.3	245	2.45	no	no
Jan-07	n/a	n/a	n/a	n/a	n/a	n/a	n/a	42517	n/a	3679.3	n/a			
Ave. Cap.	0.174													

Well Data Summary * #DIV/0! or #VALUE! = insufficient data to complete formula

Static Level	
Minimum	42.92
Maximum	43.28
Average	43.06

Pumping Level	
Minimum	42.98
Maximum	45.84
Average	44.33

Drawdown	
Minimum	-0.15
Maximum	2.65
Average	1.27

Consumption	
Minimum	0
Maximum	3110
Average	825.1
Total	9901

Total Hours	
Minimum	0
Maximum	245
Average	74.3
Total	891.7

